















- 5 WHERE A HORIZONTAL BEND IS MADE, THE PIPING SHALL BE RESTRAINED BY MEANS OF A THRUST BLOCK AS DETAILED ON THIS SHEET. WHERE VERTICAL OFFSETS ARE MADE, THE TOP BEND SHALL BE RESTRAINED BY RESTRAINING RODS AND STRAPS, CONCRETE THRUST ANCHOR BLOCKS AND RESTRAINING RODS, OR A COMBINATION OF BOTH. THE BOTTOM BENDS SHALL BE RESTRAINED BY THRUST BLOCKS AS DETAILED.

 "A","B" AND "D" DIMENSIONS SHALL BE AS LARGE AS POSSIBLE WITHOUT INTERFERRING WITH THE MECHANICAL JOINTS OR THE M.J. BOLTS.
- .4 "C" DIMENSIONS SHALL BE LARGE ENOUGH TO MAKE ANGLE $\,\theta\,$ EQUAL TO OR LARGER THAN 45".

5

- 7. "B" AND "D" DIMENSIONS SHALL PROVIDE REQUIRED BLOCKING AREA AS LISTED IN SHEETS 3 AND 4 OF THIS DETAIL. REFER TO THE SPECIFICATIONS FOR THE PRESSURE RATING OF THE PIPING SYSTEMS.

 CONCRETE SHALL BEAR ON THE CONCRETE QUADRANT OF PIPE AS A MINIMUM, SEE DETAIL ABOVE.

 THE THRUST BLOCK AREAS SHOWN ON SHEETS 3 AND 4 OF THIS DETAIL ARE CALCULATED USING A SOIL BEARING CAPACITY OF 2000 PSF. IF GREATER SOIL BEARING CAPACITY IS AVAILABLE, THE CONTRACTOR MAY, AFTER REVIEW BY THE ENGINEER, REDUCE THE THRUST BLOCK AREAS SHOWN. THE THRUST BLOCK AREA SHALL BE INCREASED IF THE SOIL IS NOT CAPABLE OF PROVIDING PSF SOIL BEARING CAPACITY.

Ņ	DETAILS - SHEET 2 OF 4	
<u></u>		REVISION DATE:
	THRIIST RESTRAINT	REVISION NO.:
	STANDARD DETAILS FOR PUBLIC IMPROVEMENTS	APPROVAL DATE: JULY 1999
	CEDAR RAPIDS METROPOLITAN AREA	FILE NO.: 2500-021

PROJECT

ö

HX0789

DRAWN BY: BGA
APPROVED BY: GMH
DATE: 10/10/2012

\	00-021
2)	
\mathcal{I}	

<u>N</u>0

APPROVAL DATE:

1999

CEDAR RAPIDS METROPOLITAN AREA STANDARD DETAILS FOR PUBLIC IMPROVEMENTS

FILE NO.:

2500-021 APRIL

REVISION DATE: REVISION NO .:

ALLTRANS, INC. Cedar Rapids, Iowa 52402 Phone: (319) 393-8726

City of Holy Cross Subdivision No.3

Dubuque County, Iowa

DETAILS

SHEET 3 OF

2500-021 <u>N</u>0

THRUST RESTRAINT

Legend, Standard Details, And Bench Mark Information

₽.10

THRUST RESTRAINT DETAILS

SIZE	
TEE OR 90-DEG 45-DEG 22.5-DEG 11.25-DEG	RESULTANT THRUST AT FITTINGS, POUNDS FOR TEST WATER PRESSURE OF 100 PSI

54	48	42	36	30	24	20	16	12	10	00	თ	4	₹	SIZE
256,072	202,683	155,528	115,209	80,425	52,279	36,644	23,779	13,685	9,677	6,433	3,739	1,810	DEAD END	TEE OR
362,140 195,989	286,637	219,950	162,931	113,738	73,934	51,822	33,628	19,353	13,685	9,097	5,288	2,559	BEND	90-DEG
195,989	155,127	119,036	88,177	61,554	40,013	28,046	18,199	10,474	7,406	4,923	2,862	1,385	BEND	45-DEG
99,914	79,083	60,684	44,952	31,380	20,398	14,298	9,278	5,340	3,776	2,510	1,459	706	BEND	22.5-DEG
50,199	39,733	30,489	22,585	15,766	10,249	7,183	4,661	2,683	1,897	1,261	733	355	BEND	11.25-DEG

MINIMUM AREA FOR THRUST BEARING, SQ. FT. FOR TEST WATER PRESSURE OF 100 PSI

48	42	36	30	24	20	16	12	10	00	თ	4	z	SIZE
			40.2		18.3	11.9	6.8	4.8	3.2	1.9	1.0	DEAD END	TEE OR
143.3	110.0	81.5	56.9	37.0	25.9	16.8	9.7	6.8	4.5	2.6	1.3	BEND	
77.6	59.5	44.1	30.8	20.0	14.0	9.1	5.2	3.7	2.5	1.4	1.0	BEND	45-DEG
39.5				10.2							1.0	BEND	
19.9	15.2	11.3	7.9	5.1	3.6	2.3	1.3	1.0	1.0	1.0	1.0	BEND	22.5-DEG 11.25-DEG

THE ABOVE AREAS ARE BASED UPON A SOIL BEARING CAPA-CITY OF 2000 PSF. IF ACTUAL SOIL BEARING STRENGTH IS LESS THAN 2000 PSF, THE THRUST BEARING AREA SHALL BE INCREASED BASED ON THE ACTUAL SOIL BEARING STRENGTH.

54

128.0

181.1

98.0

50.0

25.1